



King County

Finance and

Business Operations Division

Procurement and Contract Services Section

Department of Executive Services

EXC-FI-0825

Exchange Building, 8th Floor

821 Second Avenue

Seattle, WA 98104-1598

206-684-1327

206-684-1486 Fax

TTY Relay: 711

www.metrokc.gov

**CONSTRUCTION MANAGEMENT SERVICES FOR THE YORK AND VASHON
WASTEWATER PROJECTS
RFP No. P43010P
ADDENDUM NO. 1**

Proposers are hereby notified that the document of said Request for Proposals has been amended as hereinafter set forth:

Ref	Page	Location and Description of Change
1-1	N/A	ATTACHMENT 1 TO ADDENDUM NO. 1 Attachment 1 to Addendum No. 1 provides answers to questions received during the solicitation period.

This Addendum No.1 shall form a part of the Request for Proposals document.

Date: May 3, 2004

King County

Finance & Business Operations Division

Procurement & Contract Services Section

Exchange Building, 8th Floor, EXC-FI-0825

821 Second Avenue

Seattle, Washington 98104

Issued by:


KENNETH E. CURL
Contracts Specialist

Attachment 1
To
Addendum No. 1
RFP No. P43010P

Here are King County's responses to questions received during the solicitation period:

Question from Pat Pierce, HWA GeoSciences, Inc.

1. Will the County require a WABO registered testing agency to perform special inspections (i.e. reinforced concrete)?

Answer: The CM will not have to provide a testing lab. Special inspections will be performed by a materials testing lab under contract to the County.

Question from Sam Yaghmaie, Harris Associates

1. Please explain/define the "engineering services" under task 800 for both projects. What type of engineering services?

Answer: The CM should at a minimum have a relationship with an engineering firm that can provide multidisciplinary engineering services on an "as needed" basis. Proposers should include 150 hours in their Work Plan/LOE for engineering services.

Questions from Carl Hedberg/Kristen Wheeler, KJM Associates

1. Task 700 for both York and Vashon Scope of Work: Our question is if the Contractor is providing testing lab services paid for by the County, then per Task 700 for both Scopes, what type of field inspectors are you asking the CM to provide? Would it be: a) design/engineering inspectors; or, b.) ICBO/WABO certified inspectors?

Answer: Field inspectors should be experienced in the areas where they will be assigned by the CM and have a working knowledge of engineering requirements. They do not need to be ICBO/WABO certified.

2. Will emissions permits be required for both the Vashon and York diesel engine generators?

Answer: Permits will be obtained by the County.